



All dimming ballasts to be Lutron EcoSystem-Hi-Lume or Eco-10 type.
 E.T. to confirm all circuiting requirements.
 Architect to verify quantity, location & finish of all controls.
 All receptacles, dimmers, switches, receptacles & cable/phone jacks to be Lutron NOVA™.
 Lutron Field Service commissioning included in all systems installs on 8 year limited warranty. The electrical contractor must contact Lutron (800-523-9466) to set up visit with 10 days notice.

WIRING SYMBOLS

- 2 #12AWG (2.5 mm²)
- 3 #12AWG (2.5 mm²)
- 3 #12AWG (2.5 mm²) and 1 Twisted Pair #18AWG
- 120V Input Power
- ▲ Lutron cable GRK-CBL-246S (4 Conductor Non-Franco) or Franco (4 Conductor) or other Franco (4 Conductor) Otherwise use 2 #18AWG (1.0mm²) and 1 Belden #9461.
- Shield Jnk. requires Lutron cable SVO-CBL-250 or 2 #16(FPower), 1 #18 (Gnd) plus 4 #18 Twisted and Shielded.

GRAFIK Eye 3000 System

CONCEPT DRAWING
 NOT FOR CONSTRUCTION

Project Number:	X
Drawn By:	X
Drawing Revision:	X
Drawing Date:	X
Sheet:	X

