


TYPICAL BREAKROOM - SWITCHING

IECC 2012



MS-VPS6M2-DV-WH
VACANCY SENSOR
SINGLE POLE/MULTI-LOCATION
*NO NEUTRAL WIRE REQUIRED

SEQUENCE OF OPERATIONS:

OCCUPANT ENTERS:

- LIGHTS DO NOT AUTOMATICALLY TURN ON WHEN OCCUPANT ENTERS THE SPACE; LIGHTS MUST BE TURNED ON AUTOMATICALLY.

WHEN OCCUPIED:

- MANUAL: OCCUPANT USES WALLSWITCH TO TURN ALL LIGHTS OFF.

OCCUPANT EXITS:

- ALL LIGHTS AUTOMATICALLY TURN OFF 15 MINUTES AFTER ALL OCCUPANTS EXIT.


WIRING LEGEND:

- INPUT POWER (NORMAL)
- 2 #12AWG (4 mm²)

SYMBOL LEGEND:

\$
VS IN-WALL SWITCH / VACANCY SENSOR

Occupancy/Vacancy Sensor
Minor Motion Coverage



SENSOR COVERAGE - N.T.S.
TYPICAL OFFICE FURNITURE HEIGHTS

VIVE STANDALONE BREAKROOM

LOCATION TBD

CONCEPT DRAWING NOT FOR CONSTRUCTION

Project Number: N/A

Drawn By: RT

Drawing Revision: 6

Drawing Date:

Sheet: 1 OF 1



Lutron Electronics Co., Inc.
7200 Suter Road | Coopersburg, PA 18036 | USA
(610) 282-3800 | fax: (610) 282-1146