



PHIFER

INCORPORATED

10 October 08

LUTRON

Re: Flame Retardance of Phifer SheerWeave 7000 Products

PHIFER INCORPORATED certifies that the following material furnished by our firm:

SheerWeave 7000 – All colors

is in compliance with the following standard(s):

1. NFPA 701-2004 TM #1, Standard Methods of Fire Test for Flame Resistant Textiles and Films 2004 Edition – Test Method #1 (Small Scale).
2. Flammability per California Administrative Code, Title 19, Public Safety, Subchapter 8, Article 4, Sections 1272 (C) and referenced Article 4, Section 1237, Paragraph (b) Small Scale test.
3. British Standard 5867: Part 2: 1980 Type B Performance Requirements.
4. Uniform Building Code, 1979 Edition, Part VIII, "Fire Resistive Standard for Fire Protection", Chapter 42 – Interior Wall and Ceiling Finish, Sections 4201-4203, Class I.
5. National Fire Protection Association, NFPA No. 101, "Life Safety Code", Class "A" rating. Flame Spread Index = 10 Smoke Developed Value = 200

If you have any questions or need further information, please contact me at 205-750-4754.

Sincerely,

PHIFER INCORPORATED

Johnny Skinner
Quality Control Manager