



PHIFER
INCORPORATED

7 May 2009

Re: Flame Retardance Certification for Phifer SheerWeave Style 3000


PHIFER INCORPORATED certifies that the following material furnished by our firm:

Phifer SheerWeave 3000 Polyester/Fiberglass Vinyl Coated Fabric, all colors manufactured with ES warp yarns and containing 0.022 diameter FR-3 filling yarn is in compliance with the following standard(s):

1. NFPA 701-2004 TM #1, Standard Methods of Fire Test for Flame Resistant Textiles and Films 2004 Edition – Test Method #1 (small scale).
2. National Fire Protection Association, NFPA No. 101, "Life Safety Code", Class "A" rating.
FLAME SPREAD INDEX = 15 SMOKE DEVELOPED VALUE = 250
3. Uniform Building Code, 1979 Edition, Part VIII, "Fire Resistive Standard for Fire Protection", Chapter 42 – Interior Wall and Ceiling Finish, Sections 4201-4203. Class I.
4. Federal Motor Vehicles Safety Standard: FMVSS 302
5. NFPA 701-2004 TM#2, Flame Resistant Textiles and Films, 2004 Edition, Test 2, Large Scale – Single Flat Specimen.

If you have any questions or need further information, please contact me at 1-800-633-5955, ext 4754.

Sincerely,
PHIFER INCORPORATED


Johnny Skinner
Quality Control Manager