



# LUTRON® Product Report Card

Manufacturer: Philips  
 Model Number Tested: Fortimo Systems (DLM, LLM, and SLM) with Xitanium 913701213402  
 Other Model Numbers: None

## Manufacturer's Description

Type of device: Advance Xitanium LED Driver Control Type: 0-10V sink  
 Operating voltage: 120V/277V Dimming Range: 100% - 10%  
 Input Power: Not Specified Output Power: 15W to 36W  
 Input Current: 0.34 A max Lumen Output: Varies  
 Input Frequency: 60Hz

## Lutron Test Results

Date Tested: 16-Sep-10  
 Figure of Merit: N/A  
 Test Voltage: 120 V  
 Test Notes: Tested with Philips Fortimo LED DLM Module 1300 23W (9290 006 154)

## Lutron Recommended Compatible Products

*Lutron products not in this list can be considered to be not compatible, based on our testing.*

Product	Model Number	Fixtures per Dimmer		Measured Dimming Range <sup>(1)</sup>		Perceived Low End <sup>(2)</sup>	Comments
		Minimum	Maximum	Low End	High End		
<i>Wallbox Dimmers</i>							
Diva Nova Nova T*	DVTV NFTV NTFTV (with PP-20)	1	9	12%	99%	34%	Power pack required for line-voltage switching.
<i>Commercial Systems</i>							
Energi Savr Node	QSN-4T16-S	1	11	7%	100%	26%	Fixture flashes at start up. High and low end trim required.
Panels	TVM2 Module	1	N/A	11%	100%	34%	High end trim required.
<i>Residential Systems</i>							
Panels	TVM2 Module	1	N/A	11%	100%	34%	High end trim required.
<i>Interfaces</i>							
	GRX-TVI with DVF-103P	1	10	6%	100%	25%	High and low end trim required.
Notes:	(1) Values are based on light output using the specified dimming control, and may not be an indication of the fixture's full rated capability (2) Perceived light level percentage is the square root of the measured light level percentage, per IESNA Lighting Handbook						

Test Comments: Maximum number of supported loads is dependent on line voltage switching device's rated capacity.

*For any questions on this report, please contact the Lutron LED Center of Excellence at 877-DIM-LED8 or leds@lutron.com.  
 This information was posted with the consent and cooperation of the device manufacturer.*